GRANGE CONSTRUCTION MATERIALS

Mr Douglas A J Stewart

Kirkburn Laboratory
Kirkburn Industrial Estate
Lockerbie
Dumfries and Galloway DG11 2SE
01576710288

GRADATION ANALYSIS TEST REPORT
for Product: GQ100053A/ Recycled 4-10

Supplier/ source: Kelhead Recycling

Material type: Drystone aggregate Test method: Dry grading to BS EN 933-1

SAMPLE INFORMATION

Sampled/ tested
Mon 14 September 2015/ 18-09-15
at 1619 hrs

Sample number 18089

Customer	In House	Site	Kelhead Recycling Station
Truck No	-	Ticket No	-
Sampling Notes	-	Aggregate type	-
Weather	-	Sampled By	rd

SAMPLE ANALYSIS

Sieve size	Percent passing	Specification limits	Complies ?
20mm	100	100 - 100	yes
14mm	100	98 - 100	yes
10mm	99	85 - 99	yes
6.3mm	58	-	-
4mm	11	0 - 20	yes
2mm	1	0 - 5	yes
0.063mm	0	0 - 4	yes
Moisture content %	2.9	not specified	-

Parameters are evaluated to the accuracy of spec. limits

REMARKS

Compliance status ok
Category A of A-C excludes secondary parameters



Signed _____for Grange Quarry Date ___/___/2015