GRANGE CONSTRUCTION MATERIALS

Mr Douglas A J Stewart

Kirkburn Laboratory
Kirkburn Industrial Estate
Lockerbie
Dumfries and Galloway DG11 2SE
01576710288

GRADATION ANALYSIS TEST REPORT
for Product: GQ100061A/ Recycled Crushed Rock Fines
Supplier/ source: Kelhead Recycling

Material type: Drystone aggregate Test method: Wash grading to BS EN 933-1

SAMPLE INFORMATION

Sampled/ tested
Mon 14 September 2015/ 18-09-15
at 1619 hrs

Sample number 18090

Customer	In House	Site	Kelhead Recycling Station
Truck No	-	Ticket No	-
Sampling Notes	-	Aggregate type	Recycled
Weather	-	Sampled By	rd

SAMPLE ANALYSIS

Sieve size	Percent passing	Specification limits	Complies ?
8mm	100	100 - 100	yes
6.3mm	100	95 - 100	yes
4mm	100	85 - 100	yes
2.8mm	97	-	-
2mm	88	-	-
1mm	64	36 - 76	yes
0.500mm	44	30 - 70	yes
0.250mm	28	17 - 57	yes
0.125mm	15	-	-
0.063mm	4	0 - 16	yes
Moisture content %	16.6	not specified	-

Parameters are evaluated to the accuracy of spec. limits

REMARKS

Compliance status ok
Category A of A-C excludes secondary parameters



Signed _____for Grange Quarry Date ___/___/2015